



PRIMARY INTERIOR SUPPORT STRUCTURE (STEEL BEAM)

IF REQUIRED JOISTS CAN BE WELDED TO TOP FLANGE OF STEEL BEAM, 25mm OF 4mm FILLET WELD TO ONE SIDE OF JOIST SHOE



© SPEEDFLOOR LTD 2017

SPEEDFLOOR STANDARD DETAILS

SD2